



7469 Whitepine Rd
 North Chesterfield, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Report Number: 24-12-03823
 Received Date: 12/19/2024
 Reported Date: 12/24/2024
 Sampled By: Erick Ulloa
 Tech Certification #:

Project/Test Address: 2281; 226 Quakertown Rd; Quakertown, NJ 08868

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-03823-001	FTS-RM 103-S	12/15/2024	NURSE OFFICE RM 103 SINK	<1.00	12/23/2024	
24-12-03823-002	FTS-RM 103-WC	12/15/2024	NURSE OFFICE RM 103 WATER COOLER	<1.00	12/23/2024	
24-12-03823-003	FTS-RM 110-WC	12/15/2024	PRE-K RM RM 110 WATER COOLER	<1.00	12/23/2024	
24-12-03823-004	FTS-HRM 118- BF	12/15/2024	OUTSIDE RM 118 BOTTLE FILLER	<1.00	12/23/2024	
24-12-03823-005	FTS-HRM 118-WC	12/15/2024	OUTSIDE RM 118 WATER COOLER	<1.00	12/23/2024	
24-12-03823-006	FTS-RM 141-TL	12/15/2024	TEACHERS LOUNGE RM 141 SINK	<1.00	12/23/2024	
24-12-03823-007	FTS-CAF-BF	12/15/2024	CAFETERIA RM 135 BOTTLE FILLER	<1.00	12/23/2024	
24-12-03823-008	FTS-CAF-WC	12/15/2024	CAFETERIA RM 135 WATER COOLER	<1.00	12/23/2024	
24-12-03823-009	FTS-KITCHEN-S2	12/15/2024	CAFETERIA BACK EXIT LEFT SINK	<1.00	12/23/2024	
24-12-03823-010	FTS-KITCHEN-S3	12/15/2024	CAFETERIA BACK EXIT RIGHT SINK	2.48	12/23/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 24-12-03823

Project/Test Address: 2281; 226 Quakertown Rd; Quakertown, NJ 08868

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-03823-011	FTS-KITCHEN-S4	12/15/2024	CAFETERIA PREP SINK	3.58	12/23/2024	
24-12-03823-012	FTS-KITCHEN-S5	12/15/2024	CAFETERIA BY ENTRANCE PREP SINK	1.21	12/23/2024	
24-12-03823-013	FTS-KITCHEN-S7	12/15/2024	CAFETERIA BY ENTRANCE SINK	<1.00	12/23/2024	
24-12-03823-014	FTS-RM 153-BUB	12/15/2024	KIDERGARTEN RM 153 BUBBLER	<1.00	12/23/2024	
24-12-03823-015	FTS-RM 152-BUB	12/15/2024	KIDERGARTEN RM 152 BUBBLER	<1.00	12/23/2024	
24-12-03823-016	FTS-RM 149-BUB	12/15/2024	2ND GRADE RM 140 BUBBLER	<1.00	12/23/2024	
24-12-03823-017	FTS-RM 151-BUB	12/15/2024	1ST GRADE RM 151 BUBBLER	<1.00	12/23/2024	
24-12-03823-018	FTS-RM 148-BUB	12/15/2024	1ST GRADE RM 148 BUBBLER	1.44	12/23/2024	
24-12-03823-019	FTS-RM 148-WC	12/15/2024	HALLWAY NEXT TO RM 148 WATER COOLER	<1.00	12/23/2024	
24-12-03823-020	FTS-RM 148-BF	12/15/2024	HALLWAY NEXT TO RM 148 BOTTLE FILLER	<1.00	12/23/2024	
24-12-03823-021	FTS-RM 166-TL	12/15/2024	WORK RM RM 166 SINK	<1.00	12/23/2024	
24-12-03823-022	FTS-RM 161-S	12/15/2024	STUDENT SUPPORT SERVICES RM 161 SINK	<1.00	12/23/2024	
24-12-03823-023	FTS-BSMT-BF	12/15/2024	BASEMENT NEXT TO BOILER RM & THEATER BOTTLE FILLER	<1.00	12/23/2024	
24-12-03823-024	FTS-BSMT-WC	12/15/2024	BASEMENT NEXT TO BOILER RM & THEATER WATER COOLER	<1.00	12/23/2024	
24-12-03823-025	FTS-RM 209-BF	12/15/2024	NEXT TO RM 209 BOTTLE FILLER	<1.00	12/23/2024	
24-12-03823-026	FTS-RM 209-WC	12/15/2024	NEXT TO RM 209 WATER COOLER	<1.00	12/23/2024	
24-12-03823-027	FTS-RM 201-BF	12/15/2024	NEXT TO RM 201 BOTTLE FILLER	<1.00	12/23/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327
 Project/Test Address: 2281; 226 Quakertown Rd; Quakertown, NJ 08868

Report Number: 24-12-03823

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-12-03823-028	FTS-RM 201-WC	12/15/2024	NEXT TO RM 201 WATER COOLER	<1.00	12/23/2024	
24-12-03823-029	FTS-RM 223-BF	12/15/2024	NEXT TO RM 233 BOTTLE FILLER	<1.00	12/23/2024	
24-12-03823-030	FTS-RM 223-WC	12/15/2024	NEXT TO RM 233 WATER COOLER	<1.00	12/23/2024	
24-12-03823-031	FTS-RM 125-S	12/15/2024	MD CLASSROOM 125 SINK	<1.00	12/23/2024	
24-12-03823-032	FTS-SR	12/15/2024	SUNROOM	<1.00	12/23/2024	

Method: EPA 200.8
 Analyst: Nicole Holloway
 Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Candace Mason
 Candace Mason
 QA Chemist

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC
WaterSmart® Lead Chain-of-Custody Form
 Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
 www.leadlab.com

24-12-03823



Due Date:
 12/27/2024
 (Friday)
 AE

MW

SAMPLE NUMBERS TAKEN FROM SIDES OF BOTTLES

Client Name: LEW CORP Account #: 201327
 Address: 181 US HIGHWAY 46
 City/State/Zip: MINE HILL, NJ 07803 Phone: 908-654-8068
 Email Address: labresults@lewcorp.com
 Project Name/ Number: 2281
 Collection Address: 226 QUAKERTOWN RD City/State/Zip: QUAKERTOWN, NJ 08868
 (Required) (Required)
 Approx. Age Of Property: _____ Collected By: ERICK ULLOA
 Water Source: (Check One) Public or Well _____ Well Tag # (if applicable): _____

Turn-Around Time 5 Days 3 Days 2 Days 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	FTS-RM 103-S	NURSE OFFICE RM 103, SINK	12-15-2024	AM / PM	X	
2	FTS-RM 103-WC	NURSE OFFICE RM 103, WATER COOLER		AM / PM	X	
3	FTS-RM 110-WC	PRE-K RM, RM 110, WATER COOLER		AM / PM	X	
4	FTS-HRM 118-BF	OUTSIDE RM 118, BOTTLE FILLER		AM / PM	X	
5	FTS-HRM 118-WC	OUTSIDE RM 118, WATER COOLER		AM / PM	X	
6	FTS-RM 141-TL	TEACHERS LOUNGE RM 141, SINK		AM / PM	X	
7	FTS-CAF-BF	CAFETERIA RM 135, BOTTLE FILLER		AM / PM	X	
8	FTS-CAF-WC	CAFETERIA RM 135, WATER COOLER		AM / PM	X	
9	FTS-KITCHEN-S2	CAFETERIA BACK EXIT, LEFT SINK		AM / PM	X	
10	FTS-KITCHEN-S3	CAFETERIA BACK EXIT, RIGHT SINK		AM / PM	X	
11	FTS-KITCHEN-S4	CAFETERIA, PREP SINK		AM / PM	X	
12	FTS-KITCHEN-S5	CAFETERIA BY ENTRANCE, PREP SINK		AM / PM	X	
13	FTS-KITCHEN-S7	CAFETERIA BY ENTRANCE, SINK		AM / PM	X	
14	FTS-RM 153-BUB	KIDERGARTEN RM 153, BUBBLER		AM / PM	X	
15	FTS-RM 152-BUB	KIDERGARTEN RM 152, BUBBLER		AM / PM	X	

Released by: ERICK ULLOA Signature: *[Signature]* Date/Time: 12-17-2024
 Received by: KT HARDS Signature: *[Signature]* Date/Time: 12-19-24

11:31 AM

Client Name: **LEW CORP**

Account # **201327**

Page 2 of 2

Project Name: 2281

Lab I.D. #: 3823

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	FTS-RM 149-BUB	2ND GRADE RM 140, BUBBLER	12-15-2024	AM / PM	X	
17	FTS-RM 151-BUB	1ST GRADE RM 151, BUBBLER		AM / PM	X	
18	FTS-RM 148-BUB	1ST GRADE RM 148, BUBBLER		AM / PM	X	
19	FTS-RM 148-WC	HALLWAY NEXT TO RM 148, WATER COOLER		AM / PM	X	
20	FTS-RM 148-BF	HALLWAY NEXT TO RM 148, BOTTLE FILLER		AM / PM	X	
21	FTS-RM 166-TL	WORK RM RM 166, SINK		AM / PM	X	
22	FTS-RM 161-S	STUDENT SUPPORT SERVICES RM 161, SINK		AM / PM	X	
23	FTS-BSMT-BF	BASEMENT NEXT TO BOILER RM & THEATER, BOTTLE FILLER		AM / PM	X	
24	FTS-BSMT-WC	BASEMENT NEXT TO BOILER RM & THEATER, WATER COOLER		AM / PM	X	
25	FTS-RM 209-BF	NEXT TO RM 209, BOTTLE FILLER		AM / PM	X	
26	FTS-RM 209-WC	NEXT TO RM 209, WATER COOLER		AM / PM	X	
27	FTS-RM 201-BF	NEXT TO RM 201, BOTTLE FILLER		AM / PM	X	
28	FTS-RM 201-WC	NEXT TO RM 201, WATER COOLER		AM / PM	X	
29	FTS-RM 223 -BF	NEXT TO RM 233, BOTTLE FILLER		AM / PM	X	
30	FTS-RM 223 -WC	NEXT TO RM 233, WATER COOLER		AM / PM	X	
31	FTS-RM 125-S	MD CLASSROOM 125, SINK		AM / PM	X	
32	FTS-SR	SUNROOM		AM / PM	X	
33				AM / PM	X	
34				AM / PM	X	
35				AM / PM	X	
36				AM / PM	X	
37				AM / PM	X	
38				AM / PM	X	
39				AM / PM	X	
40				AM / PM	X	
41				AM / PM	X	
42				AM / PM		
43				AM / PM		
44				AM / PM		
45				AM / PM		
46				AM / PM		
47				AM / PM		
48				AM / PM		
49				AM / PM		
50				AM / PM		

Released by: ERICK ULLOA Signature: *[Signature]* Date/Time: 12-17-2024
 Received by: *[Signature]* Signature: *[Signature]* Date/Time: 12-19-21

11:31am