



Garden State Laboratories, Inc.

Report Date: 09/13/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Franklin Twp. Elem. School
P.O. Box 368
226 Quakertown Road
Quakertown, NJ 08868

Laboratory Director:

Attention: Lori Tirone

Client Number: FRA41

Sample ID: First Draw Lab Sample ID: 210903058-01 PWSID Number: NJ1010300
Site: Nurses 103 HS Collection Date/Time: 08/31/2021 05:57 Facility ID: DS
Matrix: Potable water Sample Type: Grab Site Code: PBCU2

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.271 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:26	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 19:46	

Sample ID: First Draw Lab Sample ID: 210903058-02 PWSID Number: NJ1010300
Site: Kitchen Far Left Collection Date/Time: 08/31/2021 06:05 Facility ID: DS
Matrix: Potable water Sample Type: Grab Site Code: PBCU5

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.202 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:30	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 19:49	

Sample ID: First Draw Lab Sample ID: 210903058-03 PWSID Number: NJ1010300
Site: DW by Kitchen Collection Date/Time: 08/31/2021 06:10 Facility ID: DS
Matrix: Potable water Sample Type: Grab Site Code: PBCU6

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0510 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:35	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:04	



Sample ID: First Draw Lab Sample ID: 210903058-04 PWSID Number: NJ1010300
 Site: Teacher's L 170 Collection Date/Time: 08/31/2021 06:03 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU7

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.113 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:39	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:12	

Sample ID: First Draw Lab Sample ID: 210903058-05 PWSID Number: NJ1010300
 Site: Teacher's L. 141 Collection Date/Time: 09/01/2021 08:20 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU13

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.150 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:44	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:15	

Sample ID: First Draw Lab Sample ID: 210903058-06 PWSID Number: NJ1010300
 Site: Kitchen Far Right Collection Date/Time: 09/01/2021 08:23 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU11

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.386 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:48	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:18	

Sample ID: First Draw Lab Sample ID: 210903058-07 PWSID Number: NJ1010300
 Site: Kit. 2nd From R Collection Date/Time: 08/31/2021 06:09 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU16

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.316 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:53	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:21	

Sample ID: First Draw Lab Sample ID: 210903058-08 PWSID Number: NJ1010300
 Site: Kitchen Far Right Collection Date/Time: 08/31/2021 06:06 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU11

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.256 mg/l	1.3	0.0100	0.0021	20044	09/09/21 14:58	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:24	



Sample ID: First Draw Lab Sample ID: 210903058-09 PWSID Number: NJ1010300
 Site: Teacher's L. 141 Collection Date/Time: 08/31/2021 05:52 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU13

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.307 mg/l	1.3	0.0100	0.0021	20044	09/10/21 10:02	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:27	

Sample ID: First Draw Lab Sample ID: 210903058-10 PWSID Number: NJ1010300
 Site: Kit. 2nd From L Collection Date/Time: 08/31/2021 06:08 Facility ID: DS
 Matrix: Potable water Sample Type: Grab Site Code: PBCU14

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.286 mg/l	1.3	0.0100	0.0021	20044	09/10/21 10:07	
Lead, Total Recoverable	EPA 200.9	1	<0.00100 mg/l	0.015	0.00100	0.00055	20044	09/07/21 20:36	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.



Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel: 800-273-8901/908-688-8900 Fax 908-688-8966 www.gs-labs.com info@gs-labs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2030 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-337-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Franklin Twp. Elem. School
 Mailing Address: P.O. Box 368
 City/State/Zip: Quakertown, NJ 08868
 Contact/Authorized by: Patricia Martucci/McGowan LLC
 Phone: 908-735-7929 X211
 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION: 226 Quakertown Rd., Quakertown, NJ

Graph Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION			Lab #		
		Date	Time	AM/PM		List Attached	Total Pages	No.		Type*	Size
X	PBCU 2 Nurses 103 HS	8/31/21	5:57	✓	Lead & Copper (First Draw)		1	P	IL	A	938-01
X	PBCU 5 Kitchen Far LK	8/31/21	6:05	✓	Lead & Copper (First Draw)		1	P	IL	A	02
X	PBCU 6 Dw by Kitchen	8/31/21	6:10	✓	Lead & Copper (First Draw)		1	P	IL	A	03
X	PBCU 7 TL170	8/31/21	6:03	✓	Lead & Copper (First Draw)		1	P	IL	A	04
X	PBCU 13 Teacher LHI	9/1/21	8:20	✓	Lead & Copper (First Draw)		1	P	IL	A	05

TURNAROUND TIME: Standard Rush (If RUSH REQUESTED, Rush Due by:)
 REPORT FORMAT: Standard Report Other Specify: _____
 Standard Report + E2 PWS ID#: NJ1010300

SEND TO: _____
 DATE/TIME: _____
 METHOD OF SHIPMENT: _____
 Amount Due: \$ _____
 Other: See Quote

Payment Method: Sampling/Pick-up Fee: \$ _____
 Composite Fee: \$ _____
 Credit Card Type: _____
 Check # _____
 Copy of Results to McGowan LLC

Note: _____

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Jim Schwyer
 Client/Client's Representative (PRINT): Jim Schwyer
 1. Received/Relinquished by (PRINT): Jim Schwyer
 2. Received/Relinquished by (PRINT): Bernard Smilgala

Date/Time: 8-31-21 13:30
 Date/Time: 9-1-21 8:35 AM
 Date/Time: 9-3-21 1:30 PM
 Date/Time: 9-3-21 13:30

The staff of Garden State Laboratories, Inc. are certified/licensed and are subject to the oversight of the state of New Jersey.
 Main Lab Certified by NJDEP #11989 and #20044
 Jersey Shore Lab Certified by NJDEP #15037

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #210044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08526 Tel. 908-537-7114

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Franklin Twp. Elem. School Contact/Authorized by: Patricia Martucci/McGowan LLC
 Mailing Address: P.O. Box 368 Phone: 908-735-7929 X211
 City/State/Zip: Quakertown, NJ 08868 Email:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION: 226 Quakertown Rd., Quakertown, NJ

Grab Cont.	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				
		Date	Time	AM PM		No.	Type*	Size	Pres.**	
X	PBCU #11 Kitchen Faucet	9/3/21	8:23	✓	Lead & Copper (First Draw)	1	P	IL	A	05806
X	PBCU #76 Kitchen Faucet	8/31/21	6:09	✓	Lead & Copper (First Draw)	1	P	IL	A	02
X	PBCU #11 Kitchen Faucet	8/31/21	6:06	✓	Lead & Copper (First Draw)	1	P	IL	A	08
X	PBCU #13 Teachers L 141	8/31/21	5:52	✓	Lead & Copper (First Draw)	1	P	IL	A	119
X	PBCU #14 Kitchen Faucet	8/31/21	6:08	✓	Lead & Copper (First Draw)	1	P	IL	A	110

Container Type: P = Plastic U = Urinal Glass V = Sterile 1000 Y = Vial Other Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sulfuric Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Hydroxide H = Ascorbic Acid I = Citric Acid J = Other Specify: _____

TURNAROUND TIME: Standard Rush (RUSH REQUESTED) Rush Due by: _____
 REPORT FORMAT: Standard Report Standard Report + E2 PWS ID#: NJ1010300
 SEND TO: _____
 DATE/TIME: _____
 METHOD OF SHIPMENT: _____

PAYMENT INFORMATION
 Amount Due: \$ _____
 Sampling/Pick-up Fee: \$ _____ Composite Fee: \$ _____
 Payment Method: Credit Card Type: _____
 Check # _____
 Other: See Quote

Note: Copy of Results to McGowan LLC

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Jim Schwarz Signature: *Jim Schwarz* Date/Time: 8-31-21
 Client/Client's Representative (PRINT): Jim Schwarz Signature: *Jim Schwarz* Date/Time: 9-1-21 8:35 Am
 1. Received/Relinquished by (PRINT): Bernard Singleton Signature: *Bernard Singleton* Date/Time: 9-3-21 13:30
 2. Received/Relinquished by (PRINT): Jim Schwarz Signature: *Jim Schwarz* Date/Time: 9-3-21 1:30 Pm

